

ANNEXURE-I**SCHEDULE OF WORK FOR SUPPLY & LAYING OF G.I STRIP FOR LIGHTING PROTECTION AND PROVIDING EARTHING FOR ELL CRANE INSTALLED AT GoI BERTH**

Sl. No.	Item	QTY	Unit	Rate	Amount
1	Supply and fixing the GI strip (6mmX 50MM) with insulator along the berth , walk way through the duct etc. for the lighting protection of the jetty crane with complete items as per latest IS.	450	mtrs		
2	Providing maintenance free Earthing system as per IS 3043, UL 467 & UL 96 standards. Providing maintenance free Earthing system comprises of molecularly bonded copper of 99.9% purity on low carbon steel of 3m length (1m (219 20 CU) x 3 nos), having a diameter of 20mm rod with copper coating thickness of 250 microns with self-coupling peg etc. complete as per annexure.	2	nos		
	TOTAL				
	GST				
	GRAND TOTAL				